

1 Overview of ground source heat extraction in Norway

2 2023

3 Total capacity and yearly developments

4 to

5 European Geothermal Energy Council (EGEC)

6
7 Anders Nerموen (NORCE)

8 7. April 2024

9 Abstract

10 Due to the lack of an updated national database keeping track of extracted of ground source heat, its
11 contribution to the national energy system relies on estimates. Two methods have been used. The NGU
12 Granada database combined with an in-house database maintained by Midttømme and Ramstad, the
13 number and depth of single wells and multiple ground source heat pump systems is provided. From data,
14 the national thermal power and energy is estimated. Moreover, the national heat pump association
15 (NOVAP) keep track of the heat pump sales.

16 In total, more than 50 MW of thermal power providing more than 160 GWh heat each year was added to
17 the national system in 2023. When summarizing from 1980s till today, it is estimated that the ground
18 source wells contribute with a peak capacity of more than 620 MW and around 2 TWh/year thermal
19 energy. When estimating the total ground source heat using the numbers from the heat pump
20 association, a power of 728 MW estimated to produce a yearly heat of 2.55 TWh.

21 The real numbers might be larger as both databases are sensitive to systematic under-reporting.
22 Moreover, the estimates are highly sensitive to assumptions of heat extraction per meter well and the
23 yearly capacity factor (i.e. hours/year of full capacity).

24 Overview of data sources

25 There is no national, complete oversight of the amount of ground source thermal energy that that has
26 been maintained over time by the government. This is related to the lack of regulative measures for the
27 extraction of heat. The heat from the ground is free of charge, it has never been taxed and thus been
28 overlooked as an asset. Therefore, there has never been any governmental incentive to keep track and
29 develop a national oversight. Moreover, since the wells are invisible (for others) and has practically zero
30 areal footprint it is not being considered in areal planning.

31 This does not mean that the information is been overlooked by all. In this report we combine data from
32 three individual data sources and combine them to provide a “best guess” of the national oversight. In
33 the following we will go through the output data from each of the three data sources, before they are

34 combined into the best guess. Then, in the last part of the report some recently developed multi-well
35 cases are presented.

36 Background to understand the value created from the ground source heat

37 We will however display some large-scale systems examples here with a brief economic analysis.
38 Typically, when large-scale systems are pr systems are reported it is the output capacity of the heating
39 and cooling system (i.e. capacity of the heat pumps) that is given. In these cases, it is important to
40 remark that the energy output of the system is a sum of the electrical energy required to run the heat
41 pumps and circulation pumps etc. plus the heat extracted from the wells, i.e. the ground source thermal
42 energy:

$$43 \quad E_{out} = E_{el} + E_{gr} \quad \text{Eqn. 1}$$

44 Even though the data often exists within the management system for each ground source heat system,
45 the temperature difference between the water out of and into the well (ΔT , in Kelvin) and the mass flow
46 rate (Q_m , in kg/hour), nor heat capacity of the fluid (C_v), is seldomly shared publicly. The heat extracted
47 from the ground ($E_{gr} = C_v \Delta T Q t$), at any given hour (t), rely on calculations from the output energy of
48 the heat pump system. Thus, the value created for the owner by the extracted ground source heat might
49 be overlooked.

50 In some cases, however, the system performance factor is given, or coefficient of performance (C_{OP})
51 defined from the ratio of the thermal energy output divided by the electrical energy needed to run the
52 operation is given via:

$$53 \quad E_{out} = C_{OP} E_{el} \quad \text{Eqn. 2}$$

54 By combining the two equations $C_{OP} E_{el} = E_{el} + E_{gr}$ we obtain $E_{el} = E_{gr} / (C_{OP} - 1)$, so when inserted
55 into Eqn. 1 yields:

$$56 \quad E_o = E_{gr} \left(1 + \frac{1}{C_{OP}-1} \right) \quad \text{Eqn. 3}$$

57 As such, if the C_{OP} is assumed (or given), one may calculate how much thermal energy that might be
58 extracted from the ground source wells (E_{gr}) from given capacity via:

$$59 \quad E_{gr} = E_o \frac{C_{OP}-1}{C_{OP}} \quad \text{Eqn. 4}$$

60 This equation is used in the presentation of the following three/four examples of recently deployed
61 ground source heat system in Norway.

62 This is to emphasize on the value of the ground source heat gained from the multi-well systems, one is
63 therefore required to subtract the electrical energy needed to operate the system, as done with the
64 equation above.

65

66 The Granada wellbore database

67 The Geological Survey of Norway (named Norges Geologiske Undersøkelser, NGU) maintains a national
68 database of drillholes drilled for water supply and ground source heat termed "Granada"
69 (https://geo.ngu.no/kart/granada_mobil/). Here, each well is registered with location, depth, date,

70 media, thickness of loose soil, yearly, and the drill-hole operator is given. The whole Granada database
71 consists of 58 594 well entries till the end of 2023. In total 11 746 km drilled length is reported.

72 In Table 1, the summary of the deployment of ground source geothermal wells in 2023 when split
73 between large multiple well systems, single houses, cabin/holiday house, farms, tourist industry and
74 unknown category. In all 4222 wells were drilled with a total length of 1021 km.

75 A histogram over the depths of single household and multiple wells system are displayed in Figure 1
76 showing that the larger multiple wells systems are typically deeper than the individual single household
77 systems. The trend over time display that the average GS heat well are getting progressively deeper
78 Figure 2.


79 The total number of wells drilled each month is displayed in Figure 3, displaying a typical range of 3-500
80 wells being drilled each month. A rather un-usual pattern is seen in November and December 2023,
81 where the number of wells plumbed almost by a factor 2. This trend is continuing into January and
82 February 2024. From personal communication with the two main drilling companies in Norway, this
83 pattern is an accurate description of the current day situation.

84 Given the oversight from NGU, the total overview revealed 60 individual companies drilling ground
85 source heat wells in 2023. The biggest providers were Båsum Boring AS and Rototec AS, followed by
86 SørNorsk Boring. All 60 providers are arranged from largest to smallest capacity (kilometers drilled) in
87 Figure 4.


88 *Table 1. Output from the Granada data base on number of wells and total drilled lengths during 2023 for larger multiple well*
89 *systems, single houses, cabins, farms, tourist industry and Unknown category. The average depth is reported.*

	Total Length, km	Number of wells, #	Avg depth, m
Larger, multiple well systems	697.2	2626	265.5
Single houses	272.1	1323	205.7
Cabin / Holiday house	24.9	141	176.4
Farms	13.8	67	205.6
Tourist industry	7.7	38	202.4
Unknown category	5.5	27	204.7
Sum	1021.2	4222	241.9


90



91
 92 *Figure 1. Histogram over the number of wells in different sized boxes: 0-50 m, 50-100m, 100-200m, 200-300m, 300-400 m, 400-*
 93 *600 m (46 wells), 600-800 m (7 wells) and more than 800 m deep wells. The larger multiple well systems are typically deeper than*
 94 *the single house wells.*




95
 96 *Figure 2. Average reported depth of ground source heat wells in the Granada database.*



98
 99 *Figure 3. Number of wells reported each month during 2023.*

100



101

102

103

104

Figure 4. Oversight of the national actors drilling geothermal ground source wells in Norway during 2023 from the national NGU database.

105

In-house overview of multiple well GSHP systems

106

107

108

109

110

Kirsti Midttømme (NORCE) and Randi Kalskin Ramstad (Asplan Viak), have for several years kept track of *large* multiple well ground source heat pump (GSHP) systems in Norway. This oversight has been shared with NGU in 2014 and an earlier version till 2013 is publicly available¹. Until today, the Midttømme-Ramstad database has 23 321 wells in 2042 GSHP systems. In 2023, 9 large-scale systems were reported with 106 wells with an average depth of 265.4 m with a total yearly length of 28.05 km.

111

112

113

There are double-counted systems/wells in the Midttømme-Ramstad and NGU database. Thus, to obtain a national estimate of ground source thermal power and yearly energy production from the drilled wells a detailed analysis to avoid double counting is required.

114

On removing double-counted wells in the database

115

116

117

118

119

120

121


122

123

124

Until recently (?), it has been voluntary to report geothermal ground source wells to the NGU database. Thus, when comparing the Midttømme-Ramstad (M-R) database to the NGU database, it becomes clear that the public database is incomplete. A rough go-through of all elements in the M-R database indicate that 60.8% of the wells were present in the Granada database in 2023. In 2017, however, approx. 70% of the wells were found in both databases, while in 2010, 2001 and all years from 1983-2000, 38.4%, 10.4% and 0.1% of the systems in the M-R were found in the Granada database. The fraction each year that has been assumed in between the counted years (shown as circles) is shown in Figure 5. Care must be taken when using the time-dependent fraction of the M-R database to be added to the Granada database, as much more work is needed to provide a more accurate estimate of the double-counted elements. This is, however, far out of reach for this report.


¹ https://www.ngu.no/upload/Georessurser/Grunnvarme/Grunnvarmeanlegg_092014.pdf



125
126
127

Figure 5. Fraction to be reported to the total overview from the Midttømme-Ramstad database. A rough assessment of double-counted elements have been obtained in the years shown as circles.

128 Figure 6 display the yearly number and total drilled length from the M-R database for large multiple well
129 GSHPs systems from 1980s through to 2023. Here, the dashed lines represent the values in the report,
130 while the solid line represent the adjusted amounts by multiplying with the fraction in Figure 5. The grey
131 lines represent the number of wells, and black lines the total drilled length.



132
133

Figure 6. Yearly output from the Midttømme-Ramstad database and the reported value downscaled with the values in Figure 5.

134 From the data above, 11 kms drilled was added to the Granada database during 2023, thus adding 0.6
135 MW heat power and an additional heat energy per year of 2.1 GWh/y to the building sector.


136 Estimating power and yearly energy extraction from the ground – using the M-R 137 database

138 A truly valuable component of the Midttømme-Ramstad is that the power is reported for 48 the GSHP
139 systems, and in 21 cases out of these also the yearly thermal energy is provided. For each case the
140 number of wells and total drilled length has also been given enabling an estimate of the yearly capacity
141 factor (i.e., number of hours in a year of full operation) and extracted heat per meter well. The heat
142 pump output originate from both the input electric energy (dissipated to heat) and the heat from the
143 ground. When the output HP capacity is multiplied by $1 - 1/C_{OP}$, where the coefficient of performance
144 (C_{OP}) is assumed to be 4.5 (on average) the heat from the ground can be calculated. It is important to
145 emphasize this, because this heat is an addition to the national energy system.

146 The average ground source power from each well as function of average depth is shown in Figure 7.
147 Here, the data is shown for different number of wells in each system. For each group of number of wells
148 the slope is given to estimate the extracted heat power per meter. As may be seen, there is a tendency

149 that by increasing number of wells the extracted power increase. An average of 52 W/m is provided
 150 (Table 2). For the 21 cases where also yearly total energy is provided, the capacity factor (in unit: h/year)
 151 can be estimated from the ratio of the reported energy (MWh/year) divided by the power (MW).

152 This data is proven useful when estimating the total power from total depth and number of wells. As
 153 such, a value of 55 W/m is used for larger parks, and a value of 30 W/m is used for single house systems.



154
 155 *Figure 7. Average heat power from the well plotted for different well park sizes. From the slope between average park depth and*
 156 *provided power, the power per meter can be determined as shown in Table 2.*

157 *Table 2. Cases reported where power and yearly energy output of the heat pump is provided in the database. The heat supply*
 158 *from the ground is estimated from an assumed coefficient of performance of 4.5. Data is divided into down for system sizes with*
 159 *given number of wells system.*

Number of wells	Cases reported with power	Power per meter, W/m	Cases reported with yearly energy	Yearly capacity factor, h/y
4-9 wells	16	37.0	2	2923
10-19 wells	19	-4.6	11	3504
20-33 wells	9	38.9	7	3895
48-180 wells	4	70.2	1	2613
Total:	48	52.1	21	3536


160

161 Estimating the total thermal extraction from the drilled
162 ground source heat wells – Combining the Midttømme-
163 Ramstad and Granada database


164 The adjusted output from Midttømme-Ramstad from 1980s till 2023 in Figure 6 was added to the yearly
165 output from the Granada database. Figure 8 display the total number of ground source heat wells, while
166 Figure 9 display the number of wells in multiple well systems and single-well systems. The yearly and
167 cumulated fraction of number of wells as part of multiple-well GSHP systems is shown in Figure 10
168 displaying a steadily increasing trend since early 2000s.

169 When multiplying the drilled length of single and multiple wells each year in Figure 11 with 35 W/m and
170 55 W/m, respectively, the power developed each year and the cumulative contribution to the national
171 energy system is shown in Figure 12. Multiplying with a capacity factor of 2500 and 3500 hours/year for
172 single and multiple well systems the yearly thermal energy contribution to the national energy system is
173 shown in Figure 13. Here, the national contribution for the single and multiple well GSHP systems are
174 singled out, while the total contribution to the national thermal ground source power and total energy is
175 provided in Figure 14 and Figure 15, respectively.


176 In 2023, 49 MW power is added to the system providing in all 161 GWh/y conflict free, firm, carbon
177 neutral energy (Table 3). In all, at the end of 2023 it is estimated that a total thermal power extracted
178 from ground source wells at a peak capacity of 617 MW (available the coldest day) supplying 1.94 TWh
179 of heat each year. This heat enable de-carbonization and the direct use of electricity that may serve
180 better purposes in our national system.




181
182 *Figure 8. Number each year and total cumulated number of ground source wells from the NGU database and the adjusted output*
183 *from the M-R database.*



184
 185 *Figure 9. Number of wells in large multiple well-systems and single well systems. Fraction of wells in large multiple well systems*
 186 *each year (dashed) and cumulated (solid). The fraction of wells in large-multiple wells system is steadily increasing.*




188
 189 *Figure 10. The fraction of wells in large multiple systems deployed each year and the total cumulative fraction.*




190
 191 *Figure 11. Total length drilled in single-well and multiple well systems each year and total since 1980s.*

192




193
 194 *Figure 12. Thermal power developed each year for single and multiple well systems. The total cumulated thermal power*
 195 *displayed with solid line.*

196




197
 198 *Figure 13. Ground source thermal energy in single and multiple well systems each year and total since 1980s.*

199



200
 201 *Figure 14. Total ground source thermal power for all wells each year and total since 1980s.*



202
 203 *Figure 15. Ground source thermal energy each year added to the system each year (dashed) and cumulated total amounts since*
 204 *1980s (solid line).*

205
 206 *Table 3. Summary of the ground source thermal power and yearly energy extracted from ground source thermal wells in Norway*
 207 *from the Granada database and the non-double counted fraction of the Midttømme-Ramstad database.*

	Developed 2023						1980s - 2023	
	Total Length, km	Number of wells, #	Well efficiency, W/m	Capacity factor, h/year	Power, MW	Thermal energy, GWh/year	Cumulated power, MW	Cumulated energy, GWh/year
Larger, multiple well systems	708.2	2642	65	3500	46.03	161.1	520.8	1822.8
Single well systems	324.0	1596	30	2500	9.72	24.3	176.3	440.7
Sum	1032.2	4238			55.8	185.4	697.1	2263.5


208
 209

210 Output from national heat pump sales database

211 Norsk Varmepumpeforening (NOVAP) have been tracing the annual heat pump sales since 1987. In this
212 context, only the fluid-fluid heat pumps are relevant, even though these systems may also be used to
213 extract heat from the sea. In all 4700 fluid-water heat pumps were sold during 2023 (orange circles in
214 Figure 16). It might be assumed that $\approx 90\%$ (???) of the heat fluid-fluid heat pump sales were used in
215 ground source heat pump systems, equating to 4230 units (dashed line). Moreover, the average lifetime
216 of a heat pump is 19-21 (?) years (varying greatly). To first order one may thus subtract the average
217 number of heat pumps sold in 2002-2004 (i.e., 1871 units) shown in blue. Thus, it might be estimated
218 that 2450 new ground source heat pump units were added to the national energy system in 2023, i.e., a
219 fraction 52-1% of the 4700 water-fluid heat pumps that were sold.

220 This number might be compared to the 4238 wells that were drilled during 2023 in 1596 single and 2642
221 multiple well units reported in the NGU and Midttømme-Ramstad data bases. In multiple-well systems, a
222 single heat pumps serve multiple wells.

223 When summing up the ground source heat pumps excluding the replacement heat pumps, around 49
224 600 GSHPs are operative in Norway.



225
226 *Figure 16. Water-fluid heat pumps sold from 1987 till 2023 (circles). The ground source (GS) heat pumps is assumed to be 90%*
227 *of the total number of units (dashed). Subtracting the replacement pumps (i.e., 15-17-year-old units in blue) the number of units*
228 *added to the national energy system are displayed by the solid orange line. Sum of all added units in black solid line equating to*
229 *approx. 49 600 units.*

230 In the NOVAP database the heat added to the building is reported. This heat originates from the
231 electricity needed to run the system and the heat added from the ground. To estimate the heat
232 extracted from the ground Eqn. 4 was used. Assuming a COP of 4.5 the fraction of heat from the ground
233 is 0.78. Table 4 provides an overview of heat pumps of various capacity enabling an estimate of the
234 number of new heat pumps added to the national system, the added power and added yearly thermal
235 energy one may extract from the ground. Assumptions for the calculation were shown in Table 5.

236 An average power and yearly energy of 14.7 kW 51 MWh is estimated from all units developed in 2023.
237 Assuming the same average power and thermal energy from the ground source heat pump systems
238 holds for all years, the total ground source thermal power and energy may be estimate from the 49 600
239 units that are estimated to be operative today as shown in Figure 17 and Figure 18, respectively.

240 In 2023, a total ground source thermal power of **728 MW** producing a yearly amount of **2.55 TWh** of
241 conflict free, carbon neutral, renewable and firm energy available also at the coldest, darkest hour
242 extracted from GSHP systems.

243 The estimates are sensitive to assumptions as described in the text.

244 *Table 4. Water-fluid heat pump (WF-HP) capacity range and number of units sold of the different types. The middle HP thermal*
 245 *power and thus, the thermal power extracted from the ground is estimated from assumptions in Table 5. Thus the ground source*
 246 *thermal power and energy added to the national energy system is estimated to be 36 MW and 126 GWh for 2023.*


WF HP capacity, kW	WF-HPs units sold	WF-GSHP units added	Avg HP thermal power, kW	Avg. Thermal power from ground, kW	GS thermal power added, MW	GS thermal energy added, GWh
>10	2028	1057	5	3.9	4.11	14.39
10-20	2122	1106	15	11.7	12.91	45.18
21-50	256	133	35	27.2	3.63	12.72
51-100	213	111	75	58.3	6.48	22.67
101-500	78	41	250	194.4	7.91	27.68
501-1000	3	2	750	583.3	0.91	3.19
> 1000	0	0	1675	1302.8	0.00	0.00
Sum	4700	2450			35.95	125.82
Average GS power per unit:			14.7	kW/unit		
Avg. yearly GS energy per unit:			51	MWh/unit		

247

248 *Table 5. Assumptions used in the calculation of thermal power and thermal ground source energy in Table 4.*


Avg. vcapacity factor GSHPs	3500	hours/year
COP (avg)	4.5	
Ground source frac	0.778	
Fraction of new 2023	52.14%	

249



250

251 *Figure 17. Added power each year (orange) and the cumulated sum of all components since 1987 till 2023 of the ground source*
 252 *heat i.e., the electrical energy is subtracted from the heat added to buildings.*



253
 254 *Figure 18. Yearly ground source thermal energy developed each year in orange, and the cumulated sum since 1987 assuming a*
 255 *fixed average capacity for each well.*

256 **Summary**

257 There is no national fully updated database that keep track of the contribution of the extraction of
 258 ground source heat. Thus, it is continuously being overlooked in the public debate. Two methods have
 259 been used to estimate the total contribution. When counting the number of ground source heat wells it
 260 the total contribution to the national thermal power and energy is provided. This is done by combing
 261 two databases. In total, 49 MW providing 161 GWh/year was added to the national system in 2023.
 262 When summarizing from 1980s till today, it is estimated that the ground source wells contribute with a
 263 peak capacity of 617 MW and 1.94 TWh/year. The estimates are highly sensitive to assumptions of heat
 264 extraction per meter well and the yearly capacity factor (i.e. hours/year of full capacity).

265 This estimate is combined with heat pump sales history from 1983 till today and the sales of various size
 266 heat pumps in 2023. When assuming a coefficient of performance, the contribution from the ground
 267 source heat is estimated. In 2023, it is estimated that a total ground source heat power of 36 MW
 268 supplying 126 GWh of yearly thermal energy is added to the system. When integrating up from 1983

269 The estimated numbers heavily rely on the assumptions used. A detailed database, allowing to add up
 270 the national contribution rather than estimating from the presented top-down analyses. Having a better
 271 oversight is required to develop policies that could facilitate the development of conflict free energy. Its
 272 contribution to the national system is crucial, as this carbon neutral energy source is available at demand
 273 – thus reducing the buildout demand for the society to meet its overall decarbonization goals.

274

275 Examples of large-scale multi-well ground source heat pump 276 systems in Norway

277 Due to the scale-free behavior, it makes energetic and economic sense to deploy also single well systems
278 to harvest ground source heat for private single households. Although, the good examples are often
279 large multi-well systems. Here, the value for the owner is evaluated in a series of examples (7th April
280 version only 1 example – more to come!).

281 Value for the owner

282 The value created by the ground source heat pump systems for the owner are two-fold: It reduces the
283 reliance of alternative energy for heating and cooling during peak-demand. As such, it reduces the
284 financial risks of extreme prices, and moreover, it provides energy for free over the year – thus reducing
285 the demand for buying energy (either molecules or electrical). To estimate relation between the yearly
286 energy production, and the power of the system, the yearly capacity factor (f_{cap} , unit: hours/year)
287 provides a useful concept. This is defined as the ratio between the yearly thermal energy output of the
288 system (E_{out} , unit: kWh/year), and the peak power (P_p , unit: kW) of heat-pump system,

$$289 \quad E_{out} = f_{cap} P_p \quad \text{Eqn. 5}$$

290 This, factor is reported when both the power and energy output is provided. In other cases, it relies on
291 estimates from similar systems. Typically, the number differs for the heating and cooling demand –
292 dictated by the local climate, the building, the geological thermal coefficients, and of-course the system
293 design and operational management.

294 The alternative cost of other energy sources that could serve the heating and cooling demand varies
295 significantly during the day, and between seasons and years. A precise estimate of the value of such a
296 system for the operator is given by the integral of 1-hour interval increments (or 15 minute) where the
297 extracted heat times and alternative cost are provided. If this data is unknown, then the value created
298 for the operator might be estimated on yearly averages are used combined with likely price scenarios.
299 The latter option is used here.

300 Value for the user – do not overlook the value for the society

301 The reduced use of electrical energy for heating and cooling purposes is freeing out energy for the
302 society, making it much easier for the society to meet its decarbonization and climate reduction goals
303 *and* enabling industry and job growth. The value is two-fold, as a reduced overall electrical energy use
304 over a normal year is key to capacity planning, but more importantly, it reduces the build-out demand of
305 the electrical transfer and power production capacity. The scale of the electrical energy system is
306 designed to meet peak demand. In the competition of area, and all associated sabotage and natural
307 risks, and material use – this is particularly valuable for all.

308 Estimating economic value for the operator

309 In its simplest form, the value created by the owner of ground source heat systems is given by an
310 overview of the expenses:

- 311 a) up-front CAPEX (CAPital EXPenses),

- 312 b) the yearly operative expenses (OPEX) to overlook, run and maintain the system, and
 313 c) an assessment of reoccurring re-investments to replace larger components (e.g., heat pumps
 314 with an average life-time expectancy of 17 years (REF?)).

315 The value created by the system is the heat extracted from the ground that reduces the alternative cost
 316 of energy. In that case Eqn. (4) is used if only the energy output from the GSHP-system to the building is
 317 given. To estimate the revenue from this, rely on the alternative cost of thermal energy, either that being
 318 the electricity cost for the consumer (including VAT and other taxes) or being the gas price. In the
 319 following two scenarios have been used, namely a price of 0.05 Euro/kWh and 0.1 Euro/kWh as yearly
 320 average – knowing that the price is often much higher (especially in Norway) when the demand for heat
 321 is the largest.

322 The internal rate of return (IRR) is a useful concept when evaluating how to spend money within a
 323 company (or family). Typically, in cases where IRR exceed the weighted average costs of capital plus a
 324 risk premium (WACC+), an investment is profitable. The estimate of IRR rely on the net cash flow (N_{CF}) is
 325 calculated from the sum of all expenses and revenues each year.

326 An alternative way to estimate the value of an investment, is to estimate the discounted net cash flow in
 327 year (t), $D_{NCF}(t)$ for each year from a given interest rate (r), the following equation is used:

328
$$D_{NCF}(t) = \frac{N_{CF}(t)}{(1-r)^t} \quad \text{Eqn. 6}$$

329 In Excel, the expenses and revenues are shown each year, together with net cash flow and discounted
 330 net cash flows are provided. An interest rate of 5% is used here. By summing up DDCF till year t one may
 331 determine the time it takes to regain the investment capital, i.e., the time for return of capital.

332 All these concepts are used to understand the reported value of each case for the operator from the
 333 assumed input factors in Table 6 used in all the examples below. Here, the CAPEX/OPEX factor, and a re-
 334 occurring CAPEX investment factor of 0.07 (i.e., 1/14th of the initial investment) occurring at an average
 335 heat pump lifetime of 15 year is used. All these assumptions are subject to change, and they will affect
 336 the overall economy lifetime. The discount rate is assumed to be constant of 5% through to 2056 (32
 337 years) and a risk premium of 1% is used. Such a low value of risk premium is used because of the
 338 maturity of the system. Moreover, when wells are drilled in crystalline rocks, the wells are extremely
 339 mechanically stable so its sensitivity to natural risks is low. The risks to sabotage is near zero, because of
 340 the low conflict potential of the energy solution compared to other energy options.

341 *Table 6. Assumptions used to evaluate the economical contribution of the examples evaluated in this report.*

Input parameters:		
Energy price, scenario 1	0.1	Euro/kWh
Energy price, scenario 2	0.05	Euro/kWh
CAPEX/OPEX factor	50	1/50
Re-occurring CAPEX reinv.	0.07	1/14
Avg heat pump lifetime	15	yr
Discount rate	5%	
Risk premium	1%	

342 **Arsenalet Industry park – Kongsberg Defense and Aerospace**

343 The newly developed 177 well ground source heat pump system developed at Arsenalet industry park,
 344 Kongsberg Norway. The ground source heat wells were drilled down to an average 300 m depth. In total
 345 53 100 m wells were drilled, at a system cost of around 30 MNOK. The work was done over 3.5 months.
 346 The energy provided by the ground source heat pump system serves both cooling and heating purposes
 347 – where cooling is performed by dumping heat from the summer into the ground. The general and
 348 specific input data for the analysis is shown in Table 6 and Table 7 respectively. The reported values are
 349 displayed in green.

350 *Table 7. Input data for the analysis of the Arsenalet industry park.*

Coefficient of performance, heat (assumed)	4.5	
Ground source factor, heating	0.78	
Coefficient of performance, cooling (assumed)	10	
Ground source factor, cooling	0.90	
Peak power of the system		
Heat	1.7	MW_h
Cooling	3.2	MW_c
Heat from ground	1.3	MW_h_g
Heat to ground (cooling)	2.9	MW_c_g
Yearly energy		
Heat to the building	2100	MWh_h/year
Heat to the ground (i.e. Building cooling)	4600	MWh_c/year
Total thermal energy to building (per design)	6700	MWh_th/year
Yearly thermal energy with the ground via wells		
Heat extracted from ground	1633	MWh_h_g/year
Heat fed to the ground (cooling)	3578	MWh_c_g/year
Total thermal energy exchange with the ground	5211	MWh_th_g/year
Estimates of yearly capacity factor		
Heating	1235	h/year
Cooling	1438	h/year

351 Based on the assumptions above the complete economic analysis can be estimated as shown in Table 8.
 352 Based on the discounted cash flow analysis the invested up-front capital is regained after 6 or 19 years,
 353 dependent upon the price scenarios for alternative energy that otherwise had to be procured. The
 354 internal rate of return (IRR) is either 22% or 7.5%, dependent upon the two price scenarios. The key
 355 output economic analysis is shown in Table 9 and Figure 19.

356

357 *Table 8. CAPEX, OPEX, revenue in price scenario 1 and 2, and net cash flow and discounted NCFs as function of time. Re-*
 358 *occurring capex after 17 years.*

Year	CAPEX	OPEX	Rev, scen 1	Rev. Scen 2	NCF, scen 1	NCF, scen. 2	Sum NCF, scen. 1	Sum NCF, scen 2	Thermal energy	Disc. NCF, scen. 1	Disc. NCF, scen. 2	Sum DNCF, scen. 1	Sum DNCF, scen. 2
------	-------	------	-------------	-------------	-------------	--------------	------------------	-----------------	----------------	--------------------	--------------------	-------------------	-------------------

	Meuro	Meuro/y	Meuro/y	Meuro/y	Meuro/y	Meuro/y	M Euro	M Euro	MWh/y	M Euro/y	M Euro/y	M Euro	M Euro
2023	€ (2.59)	€ (0.05)	€	€ 0.26	€ (2.12)	€ (2.38)	€ (2.12)	€ (2.33)	5211	€ (2.12)	€ (2.38)	€ (2.12)	€ (2.38)
2023	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ (1.65)	€ (2.07)	5211	€ 0.45	€ 0.20	€ (1.67)	€ (2.18)
2024	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ (1.18)	€ (1.80)	5211	€ 0.43	€ 0.19	€ (1.24)	€ (1.99)
2025	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ (0.71)	€ (1.54)	5211	€ 0.41	€ 0.18	€ (0.84)	€ (1.81)
2026	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ (0.24)	€ (1.28)	5211	€ 0.39	€ 0.17	€ (0.45)	€ (1.64)
2027	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 0.23	€ (1.02)	5211	€ 0.37	€ 0.16	€ (0.08)	€ (1.47)
2028	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 0.70	€ (0.76)	5211	€ 0.35	€ 0.16	€ 0.27	€ (1.32)
2029	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 1.17	€ (0.50)	5211	€ 0.33	€ 0.15	€ 0.60	€ (1.17)
2030	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 1.64	€ (0.24)	5211	€ 0.32	€ 0.14	€ 0.92	€ (1.03)
2031	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 2.11	€ 0.02	5211	€ 0.30	€ 0.13	€ 1.22	€ (0.89)
2032	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 2.58	€ 0.28	5211	€ 0.29	€ 0.13	€ 1.51	€ (0.76)
2033	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 3.05	€ 0.54	5211	€ 0.27	€ 0.12	€ 1.78	€ (0.64)
2034	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 3.52	€ 0.80	5211	€ 0.26	€ 0.12	€ 2.04	€ (0.53)
2035	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 3.99	€ 1.06	5211	€ 0.25	€ 0.11	€ 2.29	€ (0.42)
2036	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 4.45	€ 1.32	5211	€ 0.24	€ 0.11	€ 2.53	€ (0.31)
2037	€ (0.17)	€ (0.05)	€	€ 0.26	€ 0.30	€ 0.04	€ 4.75	€ 1.41	5211	€ 0.14	€ 0.02	€ 2.67	€ (0.29)
2038	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 5.22	€ 1.67	5211	€ 0.22	€ 0.10	€ 2.89	€ (0.20)
2039	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 5.69	€ 1.93	5211	€ 0.20	€ 0.09	€ 3.09	€ (0.11)
2040	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 6.16	€ 2.19	5211	€ 0.20	€ 0.09	€ 3.29	€ (0.02)
2041	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 6.63	€ 2.45	5211	€ 0.19	€ 0.08	€ 3.47	€ 0.06
2042	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 7.10	€ 2.71	5211	€ 0.18	€ 0.08	€ 3.65	€ 0.14
2043	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 7.57	€ 2.97	5211	€ 0.17	€ 0.07	€ 3.82	€ 0.22
2044	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 8.04	€ 3.23	5211	€ 0.16	€ 0.07	€ 3.98	€ 0.29
2045	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 8.51	€ 3.49	5211	€ 0.15	€ 0.07	€ 4.13	€ 0.36
2046	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 8.98	€ 3.76	5211	€ 0.15	€ 0.06	€ 4.28	€ 0.42
2047	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 9.45	€ 4.02	5211	€ 0.14	€ 0.06	€ 4.42	€ 0.48
2048	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 9.91	€ 4.28	5211	€ 0.13	€ 0.06	€ 4.55	€ 0.54
2049	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 10.38	€ 4.54	5211	€ 0.13	€ 0.06	€ 4.67	€ 0.60
2050	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 10.85	€ 4.80	5211	€ 0.12	€ 0.05	€ 4.79	€ 0.65
2051	€ -	€ (0.05)	€	€ 0.26	€ 0.47	€ 0.21	€ 11.32	€ 5.06	5211	€ 0.11	€ 0.05	€ 4.91	€ 0.70


2052	€ (0.17)	€ (0.05)	€ 0.52	€ 0.26	€ 0.30	€ 0.04	€ 11.62	€ 5.15	5211	€ 0.07	€ 0.01	€ 4.98	€ 0.71
2053	€ -	€ (0.05)	€ 0.52	€ 0.26	€ 0.47	€ 0.21	€ 12.09	€ 5.41	5211	€ 0.10	€ 0.05	€ 5.08	€ 0.76
2054	€ -	€ (0.05)	€ 0.52	€ 0.26	€ 0.47	€ 0.21	€ 12.56	€ 5.67	5211	€ 0.10	€ 0.04	€ 5.18	€ 0.80
2055	€ -	€ (0.05)	€ 0.52	€ 0.26	€ 0.47	€ 0.21	€ 13.03	€ 5.93	5211	€ 0.09	€ 0.04	€ 5.27	€ 0.84
2056	€ -	€ (0.05)	€ 0.52	€ 0.26	€ 0.47	€ 0.21	€ 13.50	€ 6.19	5211	€ 0.09	€ 0.04	€ 5.36	€ 0.88

359

360 *Table 9. Key output of capital analysis of the project.*

Output	IRR	Return of cash, yrs
Price scenario 1	22.01%	6
Price scenario 2	7.53%	19
WACC+ (5+1%)	5.00%	
Risk premium	1%	

361



362

363 *Figure 19. Cumulative discounted cash flow for an internal rate of 5% (i.e., average cost of capital). The down-payment time of*
 364 *invested capital is either 6 or 19 years dependent upon the alternative cost of energy (price scenario 1 of 0.1 Euro/kWh and*
 365 *scenario 2 is 0.05 Euro/kWh).*